

TID-14844

CALCULATION OF DISTANCE FACTORS FOR POWER AND TEST REACTOR SITES

Technical Information Document

By

J. J. DiNunno

R. E. Baker

F. D. Anderson

R. L. Waterfield

March 23, 1962

Division of Licensing and Regulation, AEC
Washington, D. C.

CALCULATION OF DISTANCE FACTORS FOR POWER
AND TEST REACTOR SITES*

Technical Information Document

By

J. J. DiNunno
F. D. Anderson
R. E. Baker
R. L. Waterfield

March 23, 1962

Division of Licensing and Regulation
U. S. Atomic Energy Commission

*Second printing--minor editorial changes made from the first printing.

T A B L E O F C O N T E N T S

	<u>Page</u>
I. PURPOSE	1
II. INTRODUCTION	3
III. BASIC CRITERIA	5
IV. POSTULATION OF MAJOR REACTOR ACCIDENT	8
V. ANALYTICAL METHOD	13
A. Fundamental Assumptions	14
B. Inhalation Dose Calculations	18
C. External Gamma Dose Calculations	25
D. Results	28
VI. COMPARISON OF ANALYTICAL METHOD TO EXISTING REACTOR SITES	35
VII. APPENDIX	37
A. Relationship of the Sutton Diffusion Parameter and the Generalized Gaussian Parameter	37
B. Bibliography	38
C. List of Symbols and Definitions	39
REFERENCES	41

I. PURPOSE

It is the intent that this document to provide reference information and guidance on procedures and basic assumptions whereby certain factors pertinent to reactor siting as set forth in Title 10 Code of Federal Regulations Part 100 (10 CFR 100)⁽¹⁾ can be used to calculate distance requirements for reactor sites which are generally consistent with current siting practices.

For any proposed reactor: the performance experience accumulated elsewhere; the engineering safeguards; the inherent stability and safety features; and the quality of design, materials, construction, management and operation are all important factors that must be included in the evaluation of the suitability of a site.

For a particular site; size, topography, meteorology, hydrology, ease of warning and removing people in times of emergency, and thoroughness of plans and arrangements for minimizing injuries and interference with offsite activities, all enter an evaluation.

Consideration of these as well as other aspects of hazards evaluation involves so many different situations and such complex technological problems that it would be quite impossible to anticipate and answer all questions that will arise.

This technical document sets forth one method of computing distances and exposures, for one general class of reactors. In developing this example conservative assumptions have been intentionally selected.

Designers of reactors are expected to examine all significant aspects of the hazards and safety problem they believe are appropriate to the particular

situation with which they are dealing. In any case, the designer and/or applicant bears the responsibility for justifying all the assumptions and methods of calculation used in a hazards evaluation. The fact that aspects of the problem are not considered in the example set forth here, does not in any way relieve the designer and/or applicant of the responsibility for carefully examining, in his particular case, every significant facet of the hazards and safety problem.

II. INTRODUCTION

An applicant for a license to construct a power or test reactor is required by Atomic Energy Commission (AEC) regulations, Title 10 Code of Federal Regulations Part 50 (10 CFR Part 50), to submit in support of his application a hazards summary report that includes details pertinent to the site proposed for the reactor. Approval or disapproval is given by the Commission after review and evaluation of the reactor design and the proposed location by the Division of Licensing and Regulation and the Advisory Committee on Reactor Safeguards (ACRS). Such review and evaluation includes an analysis of the consequences of potential accidents.

The probability and consequences of major reactor accidents have been the subject of widespread interest and study since the earliest days of reactor development. To date, however, the technology has not progressed to the point where it is possible to assign quantitative numbers to all the significant factors relative to safety or to predict with surety the probabilities of malfunctioning of engineering features of plant design under all operating conditions that might exist. There is rather general agreement, however, as expressed in the Brookhaven report, "Theoretical Possibilities and Consequences of Major Accidents in Large Nuclear Power Plants",⁽²⁾ that the probability of a major accident in reactor plants constructed and operated in accordance with general practices now observed is exceedingly small. The following is quoted from the report:

"As to the probabilities of major reactor accidents, some experts believe that numerical estimates of a quantity

so vague and uncertain as the likelihood of occurrence of major reactor accidents has no meaning. They decline to express their feeling about this probability in numbers. Others, though admitting similar uncertainty, nevertheless, ventured to express their opinions in numerical terms.... However, whether numerically expressed or not, there was no disagreement in the opinion that the probability of major reactor accidents is exceedingly low."

This low probability of occurrence is due to both the inherently safe features of reactors and the safeguards that have been engineered into the plants as a part of deliberate and planned effort to insure safety. The question of suitability of a site for a reactor, however, requires consideration not only of the factors influencing the probability of occurrence of an accident, but also the risk in terms of possible exposure of people to the hazardous consequences of such an accident. Although the probability of a serious accident may be primarily a function of facility design and the risk in terms of exposure may be primarily a function of location, the two are not independent. Site characteristics may dictate the inclusion of specific engineered safeguard features and a proposed facility design in turn may have marked influence on the acceptability of the site for location of the reactor.

Values of radiation exposure dose that can be used as reference values in the evaluation of reactor sites have been set forth in 10 CFR 100. Considerations that led to the establishment of these reference values and the site criteria in which they are embodied are discussed in the sections that follow. In addition, a hypothetical case is analyzed to illustrate the calculation of distance factors as required by 10 CFR 100.

III. BASIC CRITERIA

The AEC has set forth in 10 CFR 100 a number of the factors considered by the Commission in the evaluation of reactor sites and the general criteria used at this time as guides in approving or disapproving proposed sites. One of the factors identified is the following:

"Population density and use characteristics of the site environs, including, among other things, the exclusion area, low population zone, and population center distance."

The guides (10 CFR 100.11) also set forth pertinent factors to be considered in estimating the exclusion area, low population zone and population center distance.

Specifically, 10 CFR 100 requires an applicant for a construction permit to determine the following: (1)

"(1) An exclusion area of such size that an individual located at any point on its boundary for two hours immediately following onset of the postulated fission product release would not receive a total radiation dose to the whole body in excess of 25 rem or a total radiation dose in excess of 300 rem to the thyroid from iodine exposure.

(2) A low population zone of such size that an individual located at any point on its outer boundary who is exposed to the radioactive cloud resulting from the postulated fission product release (during the entire period of its passage) would not receive a total radiation dose to the

whole body in excess of 25 rem or a total radiation dose in excess of 300 rem to the thyroid from iodine exposure.

- (3) A population center distance of at least $1 \frac{1}{3}$ times the distance from the reactor to the outer boundary of the low population zone. In applying this guide due consideration should be given to the population distribution within the population center. Where very large cities are involved, a greater distance may be necessary because of total integrated population dose considerations."

In these criteria, two concepts are worthy of particular comment:

Note 1: Exposure Limits

The whole body dose of 25 rem referred to in the above excerpts from 10 CFR 100 corresponds numerically to the once in a lifetime accidental or emergency dose for radiation workers, which, according to NCRP recommendations⁽³⁾, may be disregarded in the determination of their radiation exposure status. However, neither its use in the context of this regulation nor that of a correspondingly low internal organ dose (such as, for example, the 300 rem to the thyroid might be considered in this application) is intended to imply that these numbers constitute acceptable emergency doses to the public under accident conditions. Rather, this 25 rem value and the 300 rem thyroid value have been set forth in these guides as reference values which can be used in the evaluation of reactor sites for reactors that reflect through their design, construction and operation an exceedingly low probability for a major accident, and through location and other safeguards against the hazardous consequences of an accident, should one occur, a low probability of public damage from such accidents. These exposure values cannot be considered as being independent from the likelihood of serious accidents nor from considerations of the total number of persons that might be exposed. They have been set forth as reasonable bases for reactor site evaluations in the context of considerations such as those indicated in Section V. of this document.

Note 2: Population Center Distance

One basic objective of the criteria is to assure that the cumulative exposure dose to large numbers of people as a consequence of any nuclear accident should be low in comparison with what might be considered reasonable for total population dose. Further, since accidents of greater potential hazard than those commonly postulated as representing an upper limit are conceivable, although highly improbable, it was considered desirable to provide for protection against excessive exposure doses of people in large centers, where effective protective measures might not be feasible. Neither of these objectives were readily achievable by a single criterion. Hence, the population center distance was added as a site requirement when it was found for several projects evaluated that the specifications thereof would approximately fulfill the desired objectives and reflect a more accurate guide to current siting practices. In an effort to develop more specific guidance on the total man-dose concept, the Commission intends to give further study to the subject. Meanwhile, in recognition of the problem, the population center distance to very large cities may have to be greater than those suggested by these guides.

IV. POSTULATION OF A MAJOR REACTOR ACCIDENT

In evaluating proposed reactor sites, the basic safety questions involve the possibility of accidents which might cause radioactivity release to areas beyond the site, the possible magnitudes of such releases and the consequences these might have. Practically, there are two difficult aspects to the estimation of potential accidents in a proposed reactor which affect the problem of site evaluation.

1. The necessity for site appraisal arises early in the life of a project when many of the detailed features of design which might affect the accident potential of a reactor are not settled.
2. The inherent difficulty of postulating an accident representing a reasonable upper limit of potential hazard.

In practice, after systematic identification and evaluation of foreseeable types of accidents in a given facility, a nuclear accident is then postulated which would result in a potential hazard that would not be exceeded by any other accident considered credible during the lifetime of the facility. Such an accident has come to be known as the "maximum credible accident".

For pressurized and boiling water reactors, for example, the "maximum credible accident" has frequently been postulated as the complete loss of coolant upon complete rupture of a major pipe, with consequent expansion of the coolant as flashing steam, meltdown of the fuel and partial release of the fission product inventory to the atmosphere of the reactor building. There may be other combinations of events which could also release significant

amounts of fission products to the environment, but in every case, for the events described above to remain the maximum credible accident the probability of their occurrence should be exceedingly small, and their consequences should be less than those of the maximum credible accident. In the analysis of any particular site-reactor combination, a realistic appraisal of the consequences of all significant and credible fission release possibilities is usually made to provide an estimate in each case of what actually constitutes the "maximum credible" accident. This estimated or postulated accident can then be evaluated to determine whether or not the criteria set out in 10 CFR 100 are met. As a further important benefit, such systematic analyses of potential accidents often lead to discovery of ways in which safeguards against particular accidents can be provided.

Since a number of analyses have indicated that the pipe rupture-meltdown sequence in certain types of water cooled reactors would result in the release of fission products not likely to be exceeded by any other "credible" accident, this accident was designated the "maximum credible accident" (MCA) for these reactors. The remainder of this discussion will refer chiefly to this type of reactor and this type of accident. Corresponding maximum credible accidents can by similar analyses be postulated for gas-cooled, liquid metal cooled, and other types of reactors.

Power and test reactors presently being operated or constructed near inhabited areas, pursuant to licenses issued by the Commission, are enclosed within external containment vessels of some type. This outer barrier to fission product release to the atmosphere has within its enclosure all or a substantial part of the primary plant coolant piping systems representing an inner barrier. Cladding on the fuel provides an additional barrier that acts as a retaining "can" for the fissionable material and the fission products formed. Thus, gross release of fission products to the atmosphere would only occur after the breaching of the two inner barriers, the fuel cladding and the primary system, and then the external barrier, the containment building.

A gross release of fission products into the reactor building might be initiated by: (1) a nuclear power excursion which would cause pressures in the primary cooling system sufficient to rupture the coolant piping or some part of the system; or (2) a failure of the piping or other parts of the system due to some defect in the materials. In either case, loss of the coolant would set the stage for possible fuel meltdown from the heat of fission product decay.

The rupture of the coolant system from high internal pressures due to uncontrolled internal heat generation would only occur after such failures as the following:

- 1) reactivity control mechanisms fail to function;
- 2) high-pressure relief systems fail to perform;
- 3) pressures exceed rupture limits of the piping material.

These prior failures need not occur for the case of a spontaneous pipe rupture. However, for such a case, the assumption of a complete shear of a pipe represents an extremely unlikely event. Nevertheless, assuming that such a break occurs and coolant is lost, fuel melting would require that:

- 1) decay heat is sufficient to increase fuel element temperature to the melting point, and
- 2) safeguard systems usually provided to flood or spray the core with water are either inoperative or insufficient to keep fuel elements from melting.

From such considerations, and from detailed analysis of the inherent self-stabilizing characteristics and engineered "accident prevention" safeguards, assurance is obtained that the likelihood of a major reactor accident is extremely small. Yet such a possibility for a serious accident cannot be completely discounted and the consequences, therefore, must be considered.

If a major release of fission products to the environment should occur, the potential exposure doses to persons off-site are extremely difficult to determine with exactness because of the complex and interwoven technical

parameters involved. The amount of each kind of radioactive material present in a reactor system can be estimated fairly closely, as a function of the power level history, but the quantity of this material that would be released as a result of an accident is unpredictable. Quantities in the order of 10 per cent of the gross activity have been assumed in the past. Experimental data would indicate these values to be conservative for accidents of the type usually visualized. The exact release can vary so much with the reactor system and with the detailed nature of an accident that the degree of conservatism in the assumptions made in any given case, is not known. Further, there is a multiplicity of possible combinations of the physical and chemical form of the radioactive materials released into the containment vessel and of the ways that atmospheric conditions might cause these radioactive materials to be transported to regions beyond the site boundary.

In accidents of the "maximum credible" type, it is usually assumed that the radioactive materials, along with erosion and corrosion products, would be dispersed in the coolant through melting or rupture of fuel elements, and then find passage to the outer containment barrier through breaches in the coolant system. On breaching, the expansion to a larger volume and a lower pressure in the containment vessel would result in steam, in addition to the gaseous fission products, and production of vapors as well as liquid and solid aerosols of a wide range of sizes. Some ejected materials may conceivably burn on contact with air, and thus increase the volatiles and fractions of fine particles. At the same time, a certain amount of the airborne fission products would be removed by such phenomena as adsorption, deposition, plate-out and steam condensation within the reactor building or containment structure. The removal process would be complicated by conversion of normally gaseous fission products into solids by decay, and condensation of volatiles. Removal by adsorption and settling processes would be affected by turbulence. Superimposed upon these factors is the radioactive decay resulting in reduction of source strength with time by

conversion to more stable isotopes. All of these factors make it difficult to determine with any exactness the radioactive content of the air which might leak out of the containment vessel.

The objective of estimating the radioactive inventory within the outer containment barrier is to attain a starting point for calculating the potential radiological hazard in the surrounding environs. For people in the proximity of the reactor building, the confined radioactive inventory represents a decaying source of direct gamma radiation which is attenuated by such factors as the structural shielding, distance, and shielding by the topography. For those at more distant points, the transport by air of the radioactive materials which might leak from the containment vessel is the major radiological consideration. For air transport, factors such as the physical nature of the material leaking from the containment vessel, release height, particle deposition with distance, wind direction, speed and variability, and air temperature gradients become important in determining the extent of these potential hazards. The meteorological factors will be a function of the region in which the reactor is located as well as the time of the day and season. Finally, when estimates have been made of the potential concentration of radioactivity likely to result at any distant point from the "maximum credible accident", there still remains a difficult problem of translating atmospheric concentrations into whole body or thyroid exposure doses to people at these points. For internal doses, the controlling ones, there are assumptions to be made about rates of breathing, percentage retention in the body, and cumulative doses to internal organs resulting from retained materials. As the last exercise, there is the problem of establishing some acceptable exposure dose criteria, within the context of this procedural operation, for a comparative measure of the acceptability or unacceptability of the estimated exposures resulting from the hypothetical accident. It is from a study of these complex interwoven technical parameters that the value for the exclusion area, low population zone and population center distance must be determined.

V. ANALYTICAL METHOD

In the procedural method described herein for calculating reactor distances for power and test reactors, the highly complex phenomena involving parameters which may vary over wide ranges of values have been made manageable by simplifying assumptions, specifying that certain secondary factors are to be ignored, and fixing the values of certain key parameters. In utilizing this method, it is recognized that:

- 1) there is a substantial degree of judgment involved in establishing the basic assumptions and assigning definitive values to variable parameters;
- 2) the results obtained are approximations, sometimes relatively poor ones, to the result which would be obtained if the effects of the full play of all the variables and influencing factors could be recognized and fixed with certainty--an impossibility in the present state of the art;
- 3) the net effect of the assumptions and approximations is believed to give more conservative results (greater distances) than would be the case if more accurate calculations could be made.

While this approach represents a considerable simplification in the handling of the many complex phenomena involved, it represents the same very conservative approach to site selection that has characterized such evaluations in the past.

A. Fundamental Assumptions

The fundamental assumptions upon which the distances are calculated with estimates of the degree of conservatism represented in each case are as follows.

1. Experts agree and experience to date, though limited, confirms that there is only an exceedingly small probability of a serious accident in reactors approved or likely to be approved for construction.⁽²⁾ The probability is still lower for an accident in which significant amounts of fission products are released into the confined primary coolant system and a great deal lower for accidents which would release significant quantities of radioactivity from the primary system into the reactor building.
2. It is assumed that the reactor is a pressurized water type for which the maximum credible accident will release into the reactor building 100 percent of the noble gases, 50 percent of the halogens and 1 percent of the solids in the fission product inventory. Such a release represents approximately 15 percent of the gross fission product activity.⁽¹¹⁾
3. Fifty percent of the iodines in the containment vessel is assumed to remain available for release to the atmosphere. The remaining fifty percent of the iodines is assumed to absorb onto internal surfaces of the reactor building or adhere to internal components. Rather than the assumed reduction factor of two, it is estimated that removal of airborne iodines by various physical phenomena such as adsorption, adherence and settling could give an effect of 3-10 reduction in the final result. Credit has not been taken for the effects of washdown or filtering from

protective safeguards such as cooling sprays and internal air recirculating systems. Washdown features and filtering networks could provide additional reduction factors of 10-1000.

4. The release of available (airborne) radioactivity from the reactor building to the environment is assumed to occur at a constant leakage rate of 0.1 per cent per day. The leakage and pressure conditions are assumed to persist throughout the effective course of the accident, which for practical purposes, would be until the iodine activity becomes insignificant. The maximum pressure within the reactor building and the leakage rate would actually decrease with time as the steam condenses from contact with cooling surfaces. By assuming no change in leak rate as a function of pressure drop, it is estimated that the final off-site doses calculated may be too high by factors of 5-10.
5. Atmospheric dispersion of material from the reactor building is assumed to occur according to the well-known relationship developed by O. G. Sutton⁽⁴⁾ involving meteorological factors of wind velocity, atmospheric stability, and diffusion parameters. Application of this treatment to reactor hazards analysis was discussed in WASH-740,⁽²⁾ and AECU-3066.⁽⁵⁾ Recently a simplified method of dispersion calculation has been proposed, by Pasquill⁽⁶⁾ and Meade,⁽⁷⁾ which reflects recent dispersion field trails, as well as current dispersion theories. In the hypothetical situation examined here the latter method gives the same numerical results as the Sutton method for distances out to about seven miles. Beyond this distance, the new method predicts somewhat greater concentrations.
6. The assumption is made that a shift in wind direction does not occur for the duration of the leakage of the fission products from the containment barrier. If leakage from the containment barrier is assumed to occur over a significant time period, (in the order of days) a reduction factor of 2-50 could result from

shifts in wind directions. Wind meandering from any one center-line direction might also result in a reduction factor of approximately 3.

7. Atmospheric dispersion is assumed to occur under inversion type weather conditions. For weather conditions which exist for 75 percent or so of the time at most sites, the atmospheric dispersion conditions could be more favorable, by factors of 5-1000.⁽⁸⁾
8. Cloud depletion as ground deposition (particulate fallout) is not assumed during cloud travel. Such deposition during cloud travel could reduce the low population zone distance by factors of 2-5.
9. In calculating the direct gamma dose, credit is not taken for shielding by the containment structure and applicable reactor shielding or topography. In some cases it is recognized that such shielding could reduce the direct gamma dose by a factor of 2-1000.
10. Decay of fission products is assumed while they are confined to the containment building but is not assumed during their transit to the receptor point. The decay enroute is not significant for the conditions of release considered here but would lower the calculated doses slightly if included.
11. In determining the whole body direct gamma dose, only the external gamma dose due to the fission products contained in the reactor building was considered significant for the assumed conditions. The whole body direct gamma dose due to the cloud passage for the assumed conditions would contribute only on the order of 1 to 10 percent of the total whole body direct gamma dose at the exclusion and low population zone distances.⁽⁵⁾

Thus, even if the postulated maximum credible accident should occur, the resulting exposure doses would probably be many times lower than those calculated by the indicated method.

On the other hand, there are potential, conceivable conditions which would result in larger fission product releases than those assumed to be released in the maximum credible accident, and the consequences could be more hazardous. Other potentially more hazardous factors than those represented by the example calculation include the following conditions.

1. Total radioactivity release to the containment vessel could theoretically be up to six times as large as those assumed. Release of long-lived fission products to the containment vessel could theoretically be up to 99 times as large as that assumed. Such releases would increase doses to the lung, bone, and total body.
2. For some sites, the atmospheric diffusion conditions for a small proportion of time could be worse than those assumed in these calculations. Such diffusion conditions could result in an increase in the inhalation doses.
3. If the external containment structure should be rendered completely ineffective at the outset of the accident, the consequences of the "maximum credible" accident would be increased many orders of magnitude. In such a case, the dose from the cloud and ground contamination could become significant in determining the external dose.

Although the analytical approach presented herein does not take into account the effects of the full play of all the variables and influencing factors, it is considered to be a reasonable procedure that results in distances roughly reflecting current siting practices for water-cooled reactors. The assumptions made can be used as a point of departure for consideration of particular site requirements resulting from evaluation of the characteristics of a particular reactor, its purpose, and the proposed plan of operation.

B. Inhalation Dose Calculations

The potential doses to the critical organs as a consequence of inhalation of a portion of the passing cloud were determined in the manner indicated below. For the specific conditions of this example, the thyroid dose is controlling and although the method is quite general, the results of the calculation are specific for the iodine release. If the type and conditions of release were different, the controlling dose could be that to the lung, bone, gut, or other critical organ.

The amount of radioactive material inhaled by a person standing a distance, d (meters), downwind for time, t (seconds), on the centerline of a cloud of radioactive material being continuously emitted from a ground level source is given by equation (1).

$$A_t = \frac{R Q_t P_0}{\pi \bar{u} \sigma_y \sigma_z} \text{ curies. (1)}$$

where:

A_t is the amount of radioactive material inhaled from the cloud, (curies), during exposure for t seconds.

R is the breathing rate, (meter³.second⁻¹).

Q_t is the amount of radioactive material in the total cloud, per megawatt reactor power, as it passes the receiver point d meters downwind, (curies.Mw⁻¹), during the time interval t .

P_0 is the rated reactor power level, (Megawatts).

\bar{u} is the average wind speed, (meters.second⁻¹).

σ_y, σ_z are standard deviations of the cloud centerline concentrations in the vertical and horizontal directions, respectively.*

$$\sigma_y = \frac{1}{\sqrt{2}} C_y d^{1-n/2}, \quad \sigma_z = \frac{1}{\sqrt{2}} C_z d^{1-n/2}$$

C_y, C_z are the virtual diffusion coefficients in the vertical and horizontal planes, respectively, (meters^{n/2}).

*See Appendix A for further discussion.

n is the stability parameter, (dimensionless).

d is the distance downwind, (meters).

Equation (1) is the time integrated expression resulting from the O. G. Sutton model of atmospheric diffusion, neglecting depletion of the cloud either by radioactive decay or scavenging during transit, multiplied by the breathing rate.

Meteorological parameters were selected to be indicative of slow dispersion at a rate estimated to occur at a reasonable frequency. Such conditions could be expected to apply between 15 percent and 25 percent of the time in most areas of the United States. They would correspond closely to Pasquill's type F, stable dispersion regime, which has a frequency of occurrence (in England) in this range, according to Beattie.⁽⁹⁾

parameter values used were:

$$\bar{u} = 1 \text{ meter} \cdot \text{sec}^{-1}$$

$$C_y = 0.40 \text{ meters}^{n/2}$$

$$C_z = 0.07 \text{ meters}^{n/2}$$

$$n = 0.5$$

$$\sigma_y = \left[\frac{1}{2} C_y^2 d^{2-n} \right]^{1/2} = \frac{0.40}{\sqrt{2}} d^{0.75}$$

$$\sigma_z = \left[\frac{1}{2} C_z^2 d^{2-n} \right]^{1/2} = \frac{0.07}{\sqrt{2}} d^{0.75}$$

The "source term", Q_r , in equation (1) will be dependent upon the amount of radioactive material which has accumulated in the reactor during operation. A simplified formula for the reactor inventory, q_t , for a specific isotope is given by equation (2).

$$q_t = \frac{P_o \times 3.2 \times 10^{16} \times \gamma_i (1 - e^{-\lambda_r T_o})}{3.7 \times 10^{10}}$$

$$q_t = 0.865 \times 10^6 P_o \gamma_i (1 - e^{-\lambda_r T_o}) \text{ (curies)} \dots \dots \dots (2)$$

Where:

q_t is the amount of isotope type i contained by the reactor at shutdown, (curies).

P_o is the rated reactor power level, (Megawatts).

3.2×10^{16} is the number of fissions. $\text{second}^{-1}.\text{megawatt}^{-1}$.

γ_i is the fission yield, ($\text{atoms}_i.\text{fission}^{-1}$).

λ_r is the radiological decay constant for the isotope, equal to

$$\frac{0.693}{T_r}, \text{ (seconds}^{-1}\text{)}.$$

T_r is the radiological half-life for the isotope, (seconds).

T_o is the time interval during which the reactor has operated, (seconds).

3.7×10^{10} is the number of disintegrations. $\text{sec}^{-1}.\text{curie}^{-1}$.

When the reactor has been operated for a time interval such that $T_o \gg T_r$, the term $e^{-\lambda_r T_o}$ becomes insignificant and the resulting formula for the "saturation" inventory, q_s , is given by equation (3).

$$q_s = 0.865 \times 10^6 P_o \gamma_i \text{ (curies)} \dots \dots \dots (3)$$

Note that this is only true when $T_o \gg T_r$, and therefore does not hold for very long-lived isotopes. The approximation is adequate for iodines but inadequate for Sr-90. Saturation values for the several iodine isotopes per Megawatt are given in Table I.

Table I. Saturation Inventory of Iodine Isotopes

Isotope	λ_r (10) (sec^{-1})	Yield ⁽¹¹⁾ (%)	$[q_s/P]$ (curies/Mw)
131	9.96×10^{-7}	2.9	2.51×10^4
132	8.26×10^{-5}	4.4	3.81×10^4
133	9.20×10^{-6}	6.5	5.63×10^4
134	2.20×10^{-4}	7.6	6.58×10^4
135	2.86×10^{-5}	5.9	5.10×10^4

The amount of a specific isotope, Q_e , per Megawatt power, which is released from the reactor building to the atmosphere during the time interval, Z , assuming constant leak rate and radioactive decay only until release, is given by equation (4).

$$Q_{\tau} = F_p F_b \left[\frac{q_t}{P} \right] \int_0^{\tau} \lambda_1 e^{-(\lambda_1 + \lambda_r)t} dt \text{ (curies} \cdot \text{Mw}^{-1})$$

$$Q_{\tau} = F_p F_b \left[\frac{q_t}{P} \right] \frac{\lambda_1}{\lambda_1 + \lambda_r} [1 - e^{-(\lambda_1 + \lambda_r)\tau}] \text{ (curies} \cdot \text{Mw}^{-1}) \dots (4)$$

Where:

- P is unit reactor power (one megawatt).
- F_p is the fraction of the isotope released from the primary containment system to the building.
- F_b is the fraction of the isotope which remains airborne and available to be released from the building to the atmosphere.
- q_t is given by equation (2).
- λ₁ is the rate of leakage from the reactor building to the atmosphere, (seconds⁻¹).
- λ_r is the radiological decay constant, (seconds⁻¹).
- τ is the time interval since the start of release during which exposure is assumed to take place, (seconds).

Consideration is given to a reactor which has been operated for a sufficiently long time period that saturation values, q_s, for the iodine isotopes may be assumed in equation (4). Furthermore, because the radii for establishing the limit of the exclusion area and the low population zone are determined by the doses resulting from two hour and infinite exposure, respectively, τ may be assumed to be 7200 seconds and infinity.

Two forms of the equation are therefore necessary for the evaluation.

For exclusion distance:


$$Q_{\tau} = F_p \times F_b \times \left[\frac{q_s}{P} \right] \frac{\lambda_1}{\lambda_1 + \lambda_r} [1 - e^{-(\lambda_1 + \lambda_r)7200}] \text{ (curies} \cdot \text{Mw}^{-1}) \dots (5)$$

For low population zone distance:

$$Q_{\tau} = F_p \times F_b \times \left[\frac{q_s}{P} \right] \frac{\lambda_1}{\lambda_1 + \lambda_r} \text{ (curies} \cdot \text{Mw}^{-1}) \dots \dots \dots (6)$$

The model assumed in developing equation (4) is somewhat oversimplified because it assumes that the fission product is formed directly by fission

process rather than through decay. Actually, most of the iodine isotopes are formed from the decay of tellurium or, as is generally the case, from the decay of antimony and tellurium. The actual formation is of the type $A \rightarrow B \rightarrow C$ rather than formation of C directly. When the half lives of the precursors are short compared to that of the iodine considered, the effect of the precursors may be ignored and the model is adequate, but when the half life of one or more of the precursors is long compared to the iodine isotope considered, that half life will be the controlling factor in the decay chain after shutdown and the source determination must consider this factor. In the case of I^{132} , the complete decay chain and half lives involved are:



If the reactor has been in operation sufficiently long to establish radiological equilibrium, the activity of the Te^{132} and the I^{132} are equal. Since the activity of I^{132} after reactor shutdown will be determined by the decay rate of the Te^{132} , equations (4), (5), and (6) may be used to determine the I^{132} source terms if the decay constant of the Te^{132} is used in place of the decay constant of I^{132} . A more exact determination of the source term for I^{131} would also consider that amount which would be produced from the $Sb^{131} \rightarrow Te^{131}$ chain subsequent to shutdown. The amount is relatively insignificant and the calculation would needlessly complicate the example.

Values for Q_y for the exclusion and low population distance can be readily determined because values for all the factors have been given or calculated. Table II contains a listing for each of the iodine isotopes and the two time periods involved using the values:

$$F_p = 0.5,$$

$$F_b = 0.5,$$

$$\lambda_1 = 0.1\% \text{ day}^{-1}.$$

$$= 0.001 \text{ day}^{-1},$$

$$\lambda_1 = 1.16 \times 10^{-8} \text{ sec}^{-1}.$$

The breathing rate, R , in equation (1) is also a variable. The "standard man"⁽¹⁰⁾ is considered to breathe 20 meters³.day⁻¹; half during the active 8 hours and the remaining half during his relatively inactive or resting

Table II Amount of Iodine Released in Time ζ

Iodine Isotope	Q_{ζ} (curies.Mw ⁻¹)	
	$\zeta = 2$ hours (Exclusion area)	$\zeta = \infty$ (Low population zone)
131	5.20×10^{-1}	7.20×10^1
132*	5.95×10^{-1}	4.42×10^1
133	1.15×10^0	1.75×10^1
134	6.80×10^{-1}	8.70×10^{-1}
135	9.65×10^{-1}	5.15×10^0

*includes Te¹³² contribution following shutdown for $\zeta = \infty$.
These values of Q_{ζ} will be used directly in evaluating equation (1).

hours. Since concern for personnel in the exclusion zone is based on two hours of inhalation, consider the breathing rate to be characteristic of the active portion of the normal work day,

$$R = 10 \text{ meters}^3/8 \text{ hours} = 3.47 \times 10^{-4} (\text{m}^3.\text{sec}^{-1}).$$

For the low population zone, the average breathing rate is assumed,

$$R = 20 \text{ meters}^3/24 \text{ hrs} = 2.32 \times 10^{-4} (\text{m}^3.\text{sec}^{-1}).$$

Since values have been given or calculated for all factors in equation (1), the amount inhaled, A_{ζ} , can be determined for various distances, d , downwind. When the amount inhaled of a specific isotope is determined, the dose to the critical organ which will be delivered by this amount can be calculated. The dose rate, D' , to the critical organ such as the thyroid at any time subsequent to the inhalation is given by equation (7).

$$\begin{aligned}
D' \text{ (rads. sec}^{-1}\text{)} &= A_{\gamma} \text{ (curies)} \times 3.7 \times 10^{10} \text{ (dis. sec}^{-1}\text{. curie}^{-1}\text{)} \\
&\times f_a \times \bar{E} \text{ (Mev. dis}^{-1}\text{)} \times 1.6 \times 10^{-6} \text{ (ergs. Mev}^{-1}\text{)} e^{-\lambda_e t} \\
&+ m \text{ (grams)} \times 100 \text{ (ergs. gm}^{-1}\text{. rad}^{-1}\text{)} \\
&= \frac{5.92 \times 10^2 A_{\gamma} f_a \bar{E} e^{-\lambda_e t}}{m} \text{ (rads. sec}^{-1}\text{)}. \dots (7)
\end{aligned}$$

Where:

A_{γ} is given by equation (1).

f_a is the fraction of the amount inhaled which is deposited in the critical organ.

\bar{E} is the effective energy absorbed by the critical organ per disintegration, (Mev).

$$\lambda_e = \lambda_r + \lambda_b = \frac{0.693}{T_e} \text{ (sec}^{-1}\text{)}.$$

λ_b is the biological elimination rate for the isotope, (sec⁻¹).

T_e is the effective half life for the isotope in the body, (sec).

m is the mass of the critical organ, (grams).

And the dose to the critical organ, delivered in time, T , is given by equation (8).

$$\begin{aligned}
D_T &= \int_0^T D' dt \\
&= \frac{5.92 \times 10^2 A_{\gamma} f_a \bar{E} \left[1 - e^{-\lambda_e T} \right]}{m \lambda_e} \text{ (rads)} \\
D_T &= \frac{8.54 \times 10^2}{m} A_{\gamma} f_a \bar{E} T_e \left[1 - e^{-\frac{0.693 T}{T_e}} \right] \text{ (rads)} \dots \dots \dots (8)
\end{aligned}$$

When the time, T , (over which the dose is determined) is much greater than the effective half life of the isotopes, the quantity, $e^{-\frac{0.693 T}{T_e}}$, becomes insignificant and the dose to the critical organ is given by equation (9).

$$D_{\infty} = \frac{8.54 \times 10^2 A_{\gamma} f_a \bar{E} T_e}{m} \text{ (rads)} \dots \dots \dots (9)$$

Using equation (9), $\frac{D_{\infty}}{A_{\gamma}}$ has been evaluated for the iodine isotopes and the values are presented in Table III.

Table III Dose to Critical Organ Per Iodine Curie Inhaled

<u>Iodine Isotope</u>	<u>T_e (sec)</u>	<u>D₀/A₀ (rads.curie⁻¹)</u>
131	6.57 x 10 ⁵	1.48 x 10 ⁶
132	8.39 x 10 ³	5.35 x 10 ⁴
133	7.52 x 10 ⁴	4.0 x 10 ⁵
134	3.11 x 10 ³	2.5 x 10 ⁴
135	2.42 x 10 ⁴	1.24 x 10 ⁵

C. External Gamma Dose Calculations

The external gamma radiation dose at the exclusion and low population zone distances due to fission products contained in the reactor building were determined in the following manner. The source of radiation was considered to be those fission products released from the primary system to the containment building--krypton, xenon, iodines, and a mixture of the remaining "solid" mixed fission products.

From a point source of radiation-given off by a specific gamma emitting isotope, the dose rate at a distance, d (meters), away in air is given by equation (10).

$$\begin{aligned}
 \text{Dose rate, } D' (\text{rads. sec}^{-1}) &= F_p \times P_o (\text{Mw}) \times \left[\frac{q_s}{P} \right] (\text{curies. Mw}^{-1}) \\
 &\times 3.7 \times 10^{10} (\text{dis. sec}^{-1} \cdot \text{curie}^{-1}) \times E_\gamma (\text{Mev. dis}^{-1}) \\
 &\times 1.6 \times 10^{-6} (\text{ergs. Mev}^{-1}) \times \mu_a (\text{meter}^{-1}) B e^{-\mu d} e^{-\lambda_r t} \\
 &+ 1.293 \times 10^3 (\text{grams. meter}^{-3}) \times 10^2 (\text{ergs. gram}^{-1} \cdot \text{rad}^{-1}) \\
 &\times 4\pi d^2 (\text{meter}^2) \dots \dots \dots (10)
 \end{aligned}$$

In equation (10), the dose buildup factor, B, is expressed by equation (10a).⁽¹²⁾

$$B = 1 + k \mu d \dots \dots \dots (10a)$$

After combining terms, equation (10) can be expressed as

$$\begin{aligned}
 D' &= 0.985 S_o \times F_p \times P_o \mu_a d^{-2} \sqrt{1 + k \mu d} e^{-\mu d} e^{-\lambda_r t} (\text{rads. sec}^{-1}) \dots \dots (11) \\
 D' &= C e^{-\lambda_r t}
 \end{aligned}$$

Where:

- S_o is the initial gamma source strength for the specific isotope at shutdown, (Mev.sec⁻¹.Mw⁻¹).
- F_p is the fraction of the isotope released to the reactor building.
- P_o is the rated reactor power level, (Mw).
- μ_a is the energy absorption coefficient, (meter⁻¹).
- k is the linear absorption constant, ($\frac{\mu - \mu_a}{\mu_a}$).
- μ is the linear absorption coefficient, (meter⁻¹).
- d is the distance to receptor, (meters).
- λ_r is the radiological decay constant, (sec⁻¹).
- t is the time after shutdown, (sec).
- C is a constant defined by the equation.

The term, S_o , combines three terms in equation (11):

$$S_o = \left[\frac{q_s}{P} \right] \times 3.7 \times 10^{10} \times E_\gamma \text{ (Mev.sec}^{-1} \cdot \text{Mw}^{-1}\text{)}.$$

Where:

- $\left[\frac{q_s}{P} \right]$ is the saturation inventory, (curies.Mw⁻¹).
- E_γ is the total gamma energy per disintegration, (Mev.dis⁻¹).
- 3.7×10^{10} is the number of disintegrations.sec⁻¹.curie⁻¹.

Table IV contains values of S_o , F_p , S_R , T_r , μ , μ_a , k , and E_{avg} for the isotopes, the "solid" mixed fission products and the gross fission products assumed to be released to the reactor building. The values of μ , μ_a , and k are energy dependent. Hence, "average" energies, E_{avg} , were selected after reviewing the weighted spectrum for each isotope and mixtures.⁽¹¹⁾ The term S_R is the product of S_o and F_p for the assumed release conditions.

Integrating the direct gamma dose rate, D' , over a specific exposure time yields the direct gamma dose.

$$D_\gamma = \int_0^t D'_R dt \text{ (rads)}$$

$$= C \int_0^t e^{-\lambda_r t} dt$$

$$D_\gamma = \frac{C}{\lambda_r} [1 - e^{-\lambda_r t}] \text{ (rads)} \dots \dots \dots (12)$$

Table IV. External Gamma Dose Data

Gamma Source	Half Life T _{1/2}	(11) "Average" Energy E (Mev)	Initial Source Strength S ₀ (Kev/sec-Mw)	Release Fraction F _p	Released Source Strength S _R (Kev/sec-Mw)	Linear (13) Absorption Coefficient μ (meter ⁻¹)	Linear (13) Absorption Constant k	Energy (13) Absorption Coefficient μ _a (meter ⁻¹)
I. Iodine								
131	8.05 days	0.4	3.63x10 ¹⁴	0.5	1.81x10 ¹⁴	1.23x10 ⁻²	2.22	3.8x10 ⁻³
132	2.4 hrs.	0.8	2.82x10 ¹⁵	0.5	1.41x10 ¹⁵	9.1x10 ⁻³	1.45	3.7x10 ⁻³
133	20.8 hrs.	0.55	1.15x10 ¹⁵	0.5	0.57x10 ¹⁵	1.08x10 ⁻²	1.85	3.9x10 ⁻³
134	52.5 mins.	1.3	3.10x10 ¹⁵	0.5	1.55x10 ¹⁵	7.2x10 ⁻³	1.10	3.4x10 ⁻³
135	6.68 hrs	1.5	2.90x10 ¹⁵	0.5	1.45x10 ¹⁵	6.7x10 ⁻³	1.02	3.3x10 ⁻³
Total Iodine	--	--	1.03x10 ¹⁶	0.5	5.16x10 ¹⁵	--	--	--
II. Xenon								
131m	12.0 days	0.163	1.50x10 ¹²	1.0	1.50x10 ¹²	1.7x10 ⁻²	4.0	3.3x10 ⁻³
133m	2.3 days	0.233	1.16x10 ¹³	1.0	1.16x10 ¹³	1.5x10 ⁻²	3.2	3.6x10 ⁻³
133	5.27 days	0.081	1.67x10 ¹⁴	1.0	1.67x10 ¹⁴	2.2x10 ⁻²	7.0	2.7x10 ⁻³
135m	15.6 mins.	0.520	2.94x10 ¹⁴	1.0	2.94x10 ¹⁴	1.1x10 ⁻²	1.9	3.9x10 ⁻³
135	9.13 hrs.	0.250	4.65x10 ¹⁴	1.0	4.65x10 ¹⁴	1.5x10 ⁻²	3.0	3.6x10 ⁻³
Total Xenon	--	--	9.40x10 ¹⁴	1.0	9.40x10 ¹⁴	--	--	--
III. Krypton								
83m	114 mins.	0.02	6.35x10 ¹²	1.0	6.35x10 ¹²	(dose considered negligible)		
85m	4.36 hrs.	0.20	8.65x10 ¹³	1.0	8.65x10 ¹³	1.6x10 ⁻²	3.5	3.5x10 ⁻³
87	78 mins.	2.00	4.84x10 ¹⁴	1.0	4.84x10 ¹⁴	5.8x10 ⁻³	0.9	3.0x10 ⁻³
88	2.77 hrs.	2.00	2.44x10 ¹⁵	1.0	2.44x10 ¹⁵	5.8x10 ⁻³	0.9	3.0x10 ⁻³
Total Krypton	--	--	3.02x10 ¹⁵	1.0	3.02x10 ¹⁵	--	--	--
IV. Mixed Fission Products (Varied)								
		0.7	3.72x10 ¹⁶	0.01	3.72x10 ¹⁴	1.0x10 ⁻²	1.6	3.8x10 ⁻³
V. Gross Fission Products								
Total of I, II, III, IV	--	--	5.15x10 ¹⁶	--	9.49x10 ¹⁵	--	--	--

*"Solid" Fission Products have an effective half-life of 2.72 hours during the first 2 hours of decay after long-time operation and have an effective decay rate which follows t^{-0.21} after the first 2 hours.

Considering the exclusion distance, the expose time is 2 hours and equation (12) becomes:

$$D_y = \frac{C}{\lambda_r} \left[1 - e^{-7200\lambda_r} \right] \text{ (rads)} \dots \dots \dots (13)$$

and for the low population zone, the exposure time is 30 days, which is several half-lives for the isotopes of the noble gases and iodine. Equation (13) for these isotopes, may be written as:

$$D_y = \frac{C}{\lambda_r} \text{ (rads)} \dots \dots \dots (14)$$

In the case of the "solid" mixed fission products the dose for the first two hours was considered to be decaying exponentially with a half-life of 2.72 hours ($\lambda_r = 7.05 \times 10^{-5} \text{ sec}^{-1}$) and subsequently as $t^{-0.21}$ based on interpretations of data from Blomeke and Todd. (11)

For the first two hours, the dose was:

$$D_y = \frac{C}{\lambda_r} \left[1 - e^{-\lambda_r \tau_1} \right] \text{ (rads)} \dots \dots \dots (15)$$

and for the 30 days, the dose was:

$$D_y = \frac{C}{\lambda_r} \left[1 - e^{-\lambda_r \tau_1} \right] + C e^{-\lambda_r \tau_1} \int_{\tau_1}^{\tau_2} t^{-0.21} dt$$

$$D_y = \frac{C}{\lambda_r} \left[1 - e^{-\lambda_r \tau_1} \right] + \frac{C e^{-\lambda_r \tau_1}}{0.79} \left[\tau_2^{0.79} - \tau_1^{0.79} \right] \text{ (rads)} \dots \dots \dots (16)$$

and since $\tau_2 \gg \tau_1$, equation (16) can be written:

$$D_y = \frac{C}{\lambda_r} \left[1 - e^{-\lambda_r \tau_1} \right] + \frac{C e^{-\lambda_r \tau_1}}{0.79} \tau_2^{0.79} \text{ (rads)} \dots \dots \dots (17)$$

The total direct gamma dose is the sum of the doses from each of the source terms as determined by equations (13) and (15) for the exclusion area and equations (14) and (17) for the low population zone.

D. Results

The results of the calculations performed for the inhalation (iodine) dose and the external gamma dose for the exclusion area ($\tau = 2$ hours) and the low population zone ($\tau = \infty$ and 30 days, respectively) are presented in

Table V. External Gamma Dose Results

Gamma Source	Direct Gamma Dose (rads/Mw)				Low Population zone ($T = 30$ days)			
	100 m	300 m	600 m	1000 m	100 m	300 m	600 m	1000 m
I. Iodine								
131	5.3×10^{-1}	1.24×10^{-1}	1.49×10^{-4}	-----	7.4×10^1	1.72×10^0	2.06×10^{-2}	9.15×10^{-5}
132	2.66×10^0	1.02×10^{-2}	3.01×10^{-3}	4.9×10^{-5}	5.95×10^0	2.26×10^{-1}	6.75×10^{-3}	1.08×10^{-4}
133	1.62×10^0	4.82×10^{-2}	9.25×10^{-4}	-----	2.44×10^0	7.25×10^{-1}	1.39×10^{-3}	1.05×10^{-4}
134	1.61×10^0	8.05×10^{-1}	3.85×10^{-3}	1.24×10^{-4}	2.02×10^0	1.02×10^{-1}	4.84×10^{-3}	1.55×10^{-4}
135	2.62×10^0	1.39×10^0	7.75×10^{-3}	2.86×10^{-4}	1.40×10^0	7.40×10^{-1}	4.11×10^{-2}	1.52×10^{-3}
Total Iodine	9.04×10^0	3.82×10^{-1}	1.57×10^{-2}	4.79×10^{-4}	1.2×10^2	3.51×10^0	7.47×10^{-2}	1.98×10^{-3}
II. Xenon								
131m	5.16×10^{-3}	5.16×10^{-5}	-----	-----	1.09×10^0	1.09×10^{-2}	3.24×10^{-4}	-----
133m	3.86×10^{-2}	5.71×10^{-4}	3.0×10^{-6}	-----	1.54×10^0	2.27×10^{-2}	1.18×10^{-4}	-----
133	6.73×10^{-1}	2.73×10^{-3}	1.83×10^{-6}	-----	6.1×10^{-1}	2.5×10^{-2}	1.68×10^{-4}	-----
135m	1.55×10^{-1}	4.62×10^{-3}	8.25×10^{-5}	-----	1.55×10^{-1}	4.6×10^{-3}	8.25×10^{-5}	-----
135	1.41×10^0	2.02×10^{-2}	1.06×10^{-4}	-----	9.7×10^0	1.4×10^{-1}	7.3×10^{-4}	-----
Total Xenon	2.28×10^0	2.82×10^{-2}	1.93×10^{-4}	-----	7.35×10^1	2.03×10^{-1}	1.42×10^{-3}	-----
III. Krypton								
83m	(negligible contribution)							
85m	2.40×10^{-1}	2.98×10^{-3}	1.14×10^{-5}	-----	8.8×10^{-1}	1.09×10^{-2}	4.2×10^{-5}	-----
87	5.4×10^{-1}	3.2×10^{-2}	2.27×10^{-3}	1.19×10^{-4}	8.25×10^{-1}	4.86×10^{-2}	3.44×10^{-3}	1.81×10^{-4}
88	3.52×10^0	2.1×10^{-1}	1.48×10^{-2}	7.75×10^{-4}	1.03×10^1	6.15×10^{-1}	4.32×10^{-2}	2.28×10^{-3}
Total Krypton	4.3×10^0	2.45×10^{-1}	1.71×10^{-2}	8.94×10^{-4}	1.2×10^1	6.75×10^{-1}	4.67×10^{-2}	2.46×10^{-3}
IV. Fission Products								
"Solids"	7.55×10^{-1}	2.52×10^{-2}	5.8×10^{-4}	6.0×10^{-6}	1.21×10^1	4.05×10^{-1}	9.25×10^{-3}	9.0×10^{-5}
V. Released Fission Products								
Total Dose	1.64×10^1	6.8×10^{-1}	3.29×10^{-2}	1.38×10^{-3}	2.18×10^2	4.79×10^0	1.32×10^{-1}	4.53×10^{-3}

Table VI. Inhalation Dose Results

Inhalation Source	Inhalation Iodine Dose (rads/MW)									
	Exclusion Radius ($\tau = 2$ hours)					Low Population Zone ($\tau = \infty$)				
	10^2 m	10^3 m	10^4 m	10^5 m		10^2 m	10^3 m	10^4 m	10^5 m	
Iodine										
131	6.02×10^{-1}	1.94×10^{-2}	6.02×10^{-3}	1.94×10^{-4}		5.6×10^2	1.79×10^1	5.6×10^{-1}	1.79×10^{-2}	
132	3.36×10^{-1}	1.08×10^{-1}	3.36×10^{-4}	1.08×10^{-5}		1.24×10^1	3.98×10^0	1.24×10^{-2}	3.98×10^{-3}	
133	3.61×10^0	1.16×10^{-3}	3.61×10^{-4}	1.16×10^{-4}		3.66×10^1	1.18×10^0	3.66×10^{-4}	1.18×10^{-6}	
134	1.33×10^{-1}	4.28×10^{-3}	1.33×10^{-4}	4.28×10^{-6}		1.14×10^{-1}	3.66×10^{-3}	1.14×10^{-3}	3.66×10^{-4}	
135	9.4×10^{-1}	3.01×10^{-4}	9.4×10^{-4}	3.01×10^{-5}		3.35×10^0	1.07×10^{-1}	3.35×10^{-3}	1.07×10^{-4}	
Total Iodine	1.10×10^1	3.55×10^{-1}	1.10×10^{-2}	3.55×10^{-4}		6.12×10^2	1.96×10^1	6.12×10^{-1}	1.96×10^{-2}	

Values Assumed for Results:

- $F_b = 0.5$
- $F_p = 0.5$
- $\bar{u} = 1$ meter.sec⁻¹
- $C_y = 0.40$ meters n/2
- $C_z = 0.07$ meters n/2
- $n = 0.5$
- $\lambda_1 = 0.1$ percent.day⁻¹

in
ga
es
es
Fig
of
dis
suc
und

Tables V and VI. Based upon these results, initial estimates of distances for reactors of various power levels have been developed and are listed in Table VII.

Table VII. Calculated Radii for Water Cooled Reactors of Various Power Levels

<u>Power Level (Mw_t)</u>	<u>Exclusion area distance (miles)</u>	<u>Low population zone distance (miles)</u>	<u>Population center distance (miles)</u>
1500	0.88 (1418 m)	13.3	17.7
1200	0.77 (1239 m)	11.5	15.3
1000	0.67 (1078 m)	10.3	13.7
900	0.63 (1012 m)	9.4	12.5
800	0.58	8.6	11.5
700	0.53	8.2	10.9
600	0.48	7.2	9.6
500	0.43	6.5	8.7
400	0.37	5.4	7.2
300	0.31	4.5	6.0
200	0.29	3.4	4.5
100	0.25	2.2	2.9
50	0.21	1.4	1.9
10	0.13	0.5	0.7

The estimated radii for power reactors are graphically represented in Figures 1 and 2. For the exclusion distance, doses from both direct gamma radiation from the reactor building and from iodine in the cloud escaping from the reactor building were calculated, and the distance established on the basis of the effect requiring the greater isolation. Figure 1 shows the thyroid and whole body doses for various power levels.

Under the conditions assumed, the doses resulting from the inhalation of the isotopes of iodine are controlling for the low population zone distance and population center distance. However, it is possible that such may not always be the case and this should be checked for each case under consideration. The low population zone distance results from




Figure 1. Exclusion Radius: Determination.




Figure 2. Population Radius Determination.

integrating the effects of iodine 131 through 135. The population center distance equals the low population zone distance increased by a factor of one-third. Figure 2 shows the relationship between the inhalation and direct dose for various power levels.

React

Dresc
Con.
Yanke
*PRDC

PWR
Consu
*Halla
Pathf

PG&E
*Phila

NASA
CVTR
Elk R
VBWR
*Piqua

*N

VI. COMPARISON OF ANALYTICAL METHOD TO EXISTING REACTOR SITES

As an indication of how the use of the above analytical method results in distances reflecting current siting practices, the method was

Table VIII. Calculated Distances for Selected Reactors

<u>Reactor</u>	<u>Power Level (Mw_t)</u>	<u>Exclusion Area</u>		<u>Low Population Area</u>	<u>Population Center Distance</u>	
		<u>Calculated Distance (miles)</u>	<u>Actual Distance (miles)</u>	<u>Calculated Distance (miles)</u>	<u>Calculated Distance (miles)</u>	<u>Actual Distance (miles)</u>
Dresden	630	0.50	0.50	7.4	9.9	14.0
Con. Ed.	585	0.48	0.30	7.0	9.4	17.0
Yankee	485	0.42	0.50	6.3	8.4	21.0
*PRDC	300	0.31	0.75	4.5	6.1	7.5
PWR	270	0.31	0.40	4.1	5.6	7.5
Consumers	240	0.30	0.50	3.9	5.2	135.0
*Hallam	240	0.30	0.25	3.9	5.2	17.0
Pathfinder	203	0.29	0.50	3.4	4.6	3.5
PG&E	202	0.29	0.25	3.4	4.6	3.0
*Phila.Elec.	115	0.26	0.57	2.4	3.2	21.0
NASA	60	0.22	0.50	1.6	2.1	3.0
CVTR	60	0.22	0.50	1.6	2.1	25.0
Elk River	58	0.22	0.23	1.5	2.0	20.0
VBWR	50	0.21	0.40	1.4	1.9	15.0
*Piqua	48	0.21	0.14	1.4	1.8	27.0

*NOTE: These reactors are not water moderated and are included in the table for illustrative purposes only. The distances for all reactors were based on the same assumption with respect to fission product release from the fuel and containment vessel and the subsequent dispersal events. There can be considerable differences between reactor types in the events that could result in a major accident and the releases that might be experienced. This must be examined on an individual basis for each reactor and the distances determined accordingly.

applied to a number of reactor projects that have been proposed or are currently authorized for construction. These results are given in Table VIII.

VII. APPENDIX

A. Relationship of the Sutton Diffusion Parameter and the Generalized Gaussian Parameter

The traditional form of the O. G. Sutton atmospheric diffusion equation describing the centerline concentration downwind of a continuous point source is generally written:

$$\frac{\mathcal{X}}{Q'} = \frac{1}{\pi \bar{u} C_y C_z d^{2-n}}$$

This equation was based on an extension of diffusion theory, an assumed homogeneous isotropic source, and an assumed three dimensional Gaussian distribution model.

When the receptor and cloud centerline are coincident with the ground level, the concentration is assumed to be doubled as a consequence of "ground reflection":

$$\frac{\mathcal{X}}{Q'} = \frac{2}{\pi \bar{u} C_y C_z d^{2-n}}$$

The diffusion coefficients, C_y and C_z are mathematical quantities which represent the diffusion capability of the atmosphere. However, Sutton and others found it necessary to determine values of C_y and C_z indirectly from data obtained through experimental field measurement. By expressing the diffusion coefficients in terms of standard deviations of the Gaussian distribution model which is assumed to describe the spatial relationship of cloud

concentration, the resulting equation may be written in the more useful form:

$$\frac{\chi}{Q'} = \frac{1}{\pi \bar{u} \sigma_y \sigma_z}$$

Where:

σ_y and σ_z are the standard deviations of the cloud concentration in the vertical and horizontal directions, respectively.

The factor of two which was introduced for "ground reflection" has been included in this equation. The equation in this form, with the Gaussian parameters, permit direct interpretation of experimental data obtained from field measurements.

The relationship between the generalized diffusion parameters (14) and the more familiar Sutton parameters (4) are expressed as:

$$\sigma_y = \frac{1}{\sqrt{2}} C_y d^{1-n/2}$$

$$\sigma_z = \frac{1}{\sqrt{2}} C_z d^{1-n/2}$$

In the generalized form, the parameters σ_y and σ_z are functions of distance and can be approximated directly from anemometer records if appropriate averaging techniques are supplied (7).

B. Bibliography

The following reference documents contain information pertaining to data obtained from various reactor projects and from associated analytical programs. The following list constitutes a brief summary of the information available on certain factors pertinent to reactor siting.

1. McCullough, C. R., Safety Aspects of Nuclear Reactors, D. Van Nostrand Company, Inc., Princeton, New Jersey, 1957.
2. Rockwell, T., "Reactor Shielding Design Manual", TID-7004, March 1956.


3. Ritchie, R. H., "Dosimetry Aspects of Nuclear Accidents", Nuclear Safety, 2(1) pp 71-75, September 1960.
4. Culver, H. N., "Maximum Credible Accident Exposures at Reactor Site Boundaries", Nuclear Safety, 2(1) pp 83-96, September 1960.
5. Progress in Nuclear Safety - Series 4, "Technology, Engineering and Safety", Hurst, R., Lyon, R. N., and Nicholls, C. M. - Editors, Pergamon Press, New York, New York, 1960.
6. Brittan, R. O., "Reactor Containment", ANL-5948, May 1959.

C. List of Symbols and Definitions

<u>Symbol</u>	<u>Represents</u>	<u>Dimensions</u>
A_z	Amount of radioactive material inhaled by an individual during a specific time period.	curies
B	Build up factor.	-
C_y, C_z	Meteorological virtual diffusion coefficients in the vertical and horizontal planes, respectively.	meters ^{n/2}
d	Distance from the source of radiation or release point.	meters
D'	Dose rate delivered by an exposure to radiation.	rads·sec ⁻¹
D_T, D_∞	Dose delivered during time interval "T" or infinite time.	rads
D_γ	Dose delivered by direct exposure to gamma radiation.	rads
\bar{E}	Effective energy absorbed by the critical organ per disintegration.	Mev·dis ⁻¹
E_{avg}	Average energy assumed for selecting values of μ .	Mev·dis ⁻¹
E_γ	Total gamma energy emitted per disintegration.	Mev·dis ⁻¹
f_a	Fraction of inhaled material which is subsequently deposited in the critical organ.	-
F_b	Fraction of material released to the reactor building and available to be released to the atmosphere.	-
F_p	Fraction of inventory released from the primary system to the reactor building.	-

List of Symbols and Definitions (Cont'd.)

<u>Symbol</u>	<u>Represents</u>	<u>Dimensions</u>
k	Linear absorption constant, $(\frac{\mu-\mu_a}{\mu_a})$.	-
m	Mass of the critical organ.	grams
n	Meteorological stability parameter.	-
P	Rated reactor power level.	Mw _t
P _o	Unit reactor power (1 megawatt).	
q _s	Saturated reactor inventory for a specific isotope.	curies
q _t	Reactor inventory for a specific isotope after a finite operating time.	curies
Q _r	Amount of a specific isotope released to the atmosphere during a finite time interval per megawatt reactor power.	curies·Mw ⁻¹
R	Breathing rate.	meters ³ ·sec ⁻¹
S _o , S _r	Source terms at shutdown - total and released to reactor building.	Mev·sec ⁻¹ ·Mw ⁻¹
t, T	Time variables.	seconds
T _o	Reactor operating time.	seconds
T _b , T _e , T _r	Biological, effective, and radiological half-lives.	seconds
\bar{u}	Average wind speed.	meters·sec ⁻¹
τ, τ_1, τ_2	Exposure time intervals.	seconds
σ_y, σ_z	Standard deviations of cloud concentration.	-
γ_1	Fission yield.	nuclei·fission ⁻¹
$\lambda_b, \lambda_e, \lambda_r$	Biological, effective, and radiological elimination and decay constants.	second ⁻¹
λ_l	Leak rate from the containments shell (reactor building)	second ⁻¹
μ, μ_a	Linear and energy absorption coefficients	meter ⁻¹



REFERENCES

1. "Reactor Site Criteria", Title 10, Code of Federal Regulations, Part 100 (10 CFR 100), February 11, 1961.
2. "Theoretical Possibilities and Consequences of Major Accidents in Large Nuclear Power Plants, " WASH-740, March 1957.
3. "Permissible Dose From External Sources of Ionizing Radiation", NBS Handbook No. 59, w/addendum of April 1958, September 24, 1954.
4. Sutton, O. G., "A Theory of Eddy Diffusion in the Atmosphere", Proceedings of the Royal Society (London), 135A:143, 1932.
5. "Meteorology and Atomic Energy", AECU-3066, July 1955.
6. Gifford, F. A. Jr., "Use of Routine Meteorological Observations for Estimating Atmospheric Dispersion", Nuclear Safety, 2(4) pp 47-51, June 1961.
7. Meade, P. J., "Meteorological Aspects of the Safety and Location of Reactor Plants", World Meteorological Organization, Technical Note No. 33, pp 13-22, 1960.
8. Hosler, C. R., "Low-Level Inversion Frequency in the Contiguous United States", Monthly weather Review, 89 pp 319-339, September 1961.
9. Beattie, J. R., "An Assessment of Environmental Hazards from Fission Product Releases", AHSB(S)R9, May 1961.
10. "Report of ICRP Committee II on Permissible Dose for Internal Radiation (1959)", Health Physics (Journal), Volume 3, June 1960.
11. Blomeke, J. O. and Todd, M. F., "Uranium-235 Fission Product Production as a Function of Thermal Neutron Flux, Irradiation Time, and Decay Time", ORNL-2127, Part 1, Volume 1 and 2, November 1958.
12. Goldstein, H., The Attenuation of Gamma Rays and Neutrons in Reactor Shields, May 1957.
13. The Reactor Handbook, AECD-3645, Volume 1, "Physics", February 1955.
14. Gifford, F. A. Jr., "Atmospheric Dispersion Calculations Using the Generalized Gaussian Plume Model", Nuclear Safety, 2(2) pp 56-59, December 1960.